

# MOBILE COUNTY COMMISSION

COUNTY COMMISSIONERS  
CONNIE HUDSON, PRESIDENT  
MERCERIA LUDGOOD, COMMISSIONER  
JERRY L. CARL, COMMISSIONER

TELEPHONE (251) 574-5077



ADMINISTRATION  
JOHN F. PAFENBACH  
COUNTY ADMINISTRATOR

GLENN L. HODGE  
DEPUTY ADMINISTRATOR

TELEPHONE (251) 574-8606  
FAX (251) 574-5080

## ***ADDENDUM #4***

**TO:** ALL VENDORS

**FROM:**

  
**Susan Y. Holland-Purchasing Agent**  
**MOBILE COUNTY COMMISSION**

**DATE:** May 21, 2014

**RE: BID 28-14- GOVERNMENT PLAZA NORTH TOWER RESTORATION  
SERVICES FOR MOBILE COUNTY COMMISSION:**

**Please review the following:**

- 1. Questions and answers.**
- 2. Revised Addendum Acknowledgement page.**

Mobile County would like to apologize for any inconvenience. Thank you for your cooperation.

May 21, 2014

Mobile County Bid Inv 28-14

Additional Questions and Information

What is square foot load limit for Atrium Roof? **Roof Live Load is 20 PSF**

What is square foot load limit for Atrium floor? **Atrium Floor Live Load limit is 100 PSF. Law Library Live Load Limit is 150 PSF.**

The Law Library is not in the detailed scope? **Correct, an updated detail on this scope will be provided. This cost should not be included in the bids.**

The scope only says to clean exterior glass of soot. More detail is requested.

**This should not be included in bid until further detailed information is available.**

The rough scope and detailed xactimate scope shows replacing the carpet on 8<sup>th</sup> floor Court Rooms and Jury Assembly Rooms. **This is Correct and carpet is to be replaced in those areas as indicated in the xactimate scope. Carpet areas in rooms/offices north of the Court Rooms and Jury Assembly room are to be cleaned.**

The detailed scope of work says remove and replace suspended ceiling system. Does this include grids? **Yes, grid system needs to be replaced where indicated in detailed xactimate scope.**

**Additional information for all:**

**YOUR BID SHOULD BE BASED ON THE DETAILED/XACTIMATE SCOPE (273 PAGES) PROVIDED TO YOUR COMPANY, ADDITIONAL WORK WILL BE ADDRESSED ONCE MORE DETAIL IS AVAILABLE.**


**Ceiling tiles currently used in affected areas: USG Ceiling pt# 8223 or Armstrong pt # 770.**

**Paint used in common areas currently is "Sherman Williams Garbo Silver."**

**No asbestos study or survey completed in last five years at Government Plaza.**

## ADDENDUM ACKNOWLEDGEMENT FORM

**TO:** ALL VENDORS

**FROM:**   
Susan Y. Holland-Purchasing Agent  
MOBILE COUNTY COMMISSION

**DATE:** May 21, 2014

**RE: BID 28-14- GOVERNMENT PLAZA NORTH TOWER RESTORATION  
SERVICES FOR MOBILE COUNTY COMMISSION:  
BID OPENING MAY 22, 2014, 10:00 A.M.**

ACKNOWLEDGEMENT OF ADDENDUM 1 \_\_\_\_\_

ADDEMDUM 2 \_\_\_\_\_

ADDENDUM 3 \_\_\_\_\_

ADDENDUM 4 \_\_\_\_\_